

MANUFACTURER`S DECLARATION OF CONFORMITY (EU/UK)

Manufacturers Name: KATKO Oy

Manufacturer Address: Ruosilantie 2,
FIN-00390 HELSINKI, FINLAND

We hereby declare that the products

Product type: Enclosed Switch disconnecter / Isolator with part number

KEM/KUM/KEA/KUA/KET/KUT/KER/KUR/KSM/KE/TKM/PVM
PVA/ KKVM/KKVR/KKVT/KVKEM/KVKET/KVKER/KEF/PSM

might be followed by 1/2/3/4/6/8 and
10/16/25/32/40/63/80/125/160/200/250/315/400/630/800/1000/1250/1600

might be followed by EMC, then EMC EN 61000-6-3:2007+A1(2011)
might be followed by EX, then EN 60079-3 (2012), EN 60079-31(2014)
might be followed by FR, then 200 °C 3h, conforming to EN 12101-3
might be followed by FR3, then 300 °C 2h, conforming to EN 12101-3

Product type: Load break switch /Switch Fuse / Isolator with part number

KU/KUE/EVA/VKA/VKE/KVKE/PV/KS
might be followed by 1/2/3/4/6/8 (Number of poles) and
10/16/25/32/40/63/80/125/160/200/250/315/400/630/800
(Current ratings in Amps)

have been designed and manufactured in accordance with latest standards:

IEC 60947-1
IEC 60947-3
Low Voltage Directive 2014/35/EU
Atex Directive 2014/34/EU, SI 2016 No. 1107
IEC 60529
ISO 9001:2015

Helsinki 10.01.2022

KATKO Oy

Senior Manager
QA & Testing