



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，  
不得单独使用  
This translated document  
does not have legal validity and  
cannot be used in isolation

**CERTIFICATE NO.:** 2024010302705807

**NAME AND ADDRESS OF THE APPLICANT**

Katko Oy  
Ruosilantie 2, 00390 Helsinki, Finland

**NAME AND ADDRESS OF THE MANUFACTURER**

Katko Oy  
Ruosilantie 2, 00390 Helsinki, Finland

**NAME AND LOCATION OF THE FACTORY**

Katko Oy  
Ruosilantie 2, 00390 Helsinki, Finland

**PRODUCT NAME,MODEL AND SPECIFICATION**

Isolator Switch  
TK 616/316/316S VV ; See the Appendix

**STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T 14048.3-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

**Valid from:** Oct.24,2024

**Valid until:** Oct.23,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，  
不得单独使用  
This translated document  
does not have legal validity and  
cannot be used in isolation

CERTIFICATE NO. : 2024010302705807

Appendix : Page 1 of 1

TK 616/316/316S VV

Uimp: 8kV;

Ui: 690V;

Ith: 25A;

Ue: AC415V;

Ie: 16A;

Icw: 1.1kA/1s;

Icm(peak): 1.5kA;

AC-21A, AC-22A, AC-23A;

3P;

50/60Hz;

Attached Auxiliary Contacts:

Ith: 6A;

AC-12:Ue/Ie:AC220V/16A,

AC-15:Ue/Ie:AC220V/4A,

DC-12:Ue/Ie:DC220V/4A,

DC-13:Ue/Ie:DC220V/0.5A;

1NO1NC,2NO2NC

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.